



CITY OF LAMESA

601 South First • 806/872-2124
LAMESA, TEXAS 79331-6247

Triggered Source Monitoring and Reporting Violation: Ground Water Rule

The City of Lamesa # 0580001 failed to collect the required number of triggered source bacteriological samples for fecal indicator monitoring of the ground water system during September 2015. This monitoring is required by the Texas Commission on Environmental Quality's "Drinking Water Standards" and the federal "Safe Drinking Water Act," Public Law 95-523.

Triggered source samples are used to monitor water quality and indicate if the water is free of fecal indicator bacteria. Following a positive routine total coliform result in our distribution system, our water system is required to submit one triggered source sample for every active ground water well. Failure to collect all required source samples is a violation of the monitoring requirements and we are required to notify you of this violation.

If you have any questions regarding this violation, you may contact Dionicio Garza, Jr at 1-806-872-2124 or 1-806-332-9036.